

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF HENDRON WATER)	
DISTRICT FOR A DEVIATION FROM THE)	CASE NO. 89-114
STORAGE REQUIREMENTS OF 807 KAR)	
5:066, SECTION 5(4))	

O R D E R

By letter filed on April 24, 1992, the Hendron Water District ("Hendron") requested additional time to comply with Commission Regulation 807 KAR 5:066, Section 5(4), which requires that each utility shall maintain water storage to ensure a minimum of one day's supply of its average daily water usage. On May 19, 1989, the Commission ordered Hendron to bring its water storage facilities into compliance with Commission regulations by June 1, 1992.

On April 24, 1992, Hendron informed the Commission that Kentucky Infrastructure Authority ("KIA") has approved financing for construction of a new elevated storage tank. Hendron further stated that it needed until January 1, 1993 to bring its water storage requirement in compliance with the May 19, 1989 Order.

The Commission, having reviewed the information submitted and being otherwise sufficiently advised, finds that Hendron is making substantial progress toward bringing its facilities into compliance with the Commission's Order of May 19, 1989, and that additional time is necessary to comply with the requirements of Commission Regulation 807 KAR 5:066, Section 5(4).


IT IS THEREFORE ORDERED that:

1. Hendron be and it hereby is granted a deviation until January 1, 1993 to comply with the provisions of 807 KAR 5:066, Section 5(4).

2. Hendron shall take all necessary action to bring its water storage facilities into compliance with Commission regulations prior to January 1, 1993.

Done at Frankfort, Kentucky, this 14th day of May, 1992.

PUBLIC SERVICE COMMISSION


Chairman


Vice Chairman


Commissioner

ATTEST:


Executive Director, Acting